



FOR IMMEDIATE RELEASE  
November 20, 2023

CONTACT: Jack Hughes, Project Engineer  
517.853.4470 | [hughes@meridian.mi.us](mailto:hughes@meridian.mi.us)

**ADDENDUM #1**

*County Park West Sewer Replacement 2023*

Addendum #1 includes five (5) revised contract pages: P-2, SP-2, SP-5, SP-6, APX-A and two (2) revised Plan Sheets: 2, 5.

**Please note: you must sign this addendum and include it with your proposal.**

This addendum is intended to answer common questions, remove a pay item, remove asphalt re-pavement requirements and clarify the relevant diagrams and special provisions.

Extra Sand Backfill

- 1) Pay Item 3 "Extra Sand Backfill" has been removed from the Proposal. Previously this backfill quantity was to be paid for separately under its own line item. It has been revised so that *all backfill is now incidental to the construction of the sewers.* Plan Sheet 2 and the Special Provisions of items 20a-20c, the Sanitary Sewers, have been altered to reflect this.

Pavement Restoration

- 2) Pay Item 2b "Pavt, Restoration, County Park Boat Launch" has been changed to *no longer require hot mix asphalt* as part of the restoration to its pre-construction state. Instead 21AA aggregate road base or Millings will be used to create a substitute surface, similar to Pay Item 2a. The Appendix A - "Special Trench Detail" and Plan Sheet 5 have been updated to show this.
- 3) To clarify, we are not expecting Quail St and E Reynolds Rd to be re-paved upon completion.

Date	_____	Company Name	_____
By	_____	Address	_____
	Signature		
	_____		_____
	Printed Name		
Title	_____	Phone Number	_____
		Email Address	_____

The community of Meridian Township is in close proximity to the Michigan State Capitol and Michigan State University. The Township serves the community through exceptional services, beneficial amenities and an outstanding quality of life. It is a welcoming community that celebrates quality education, recreation and lifestyles.

